Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 439

Customer			*Sample Collection*	
Facility Name:	*Seneca Valley H.S.*		*Date:*	6/3/25
			Time:	2:00 PM
Address:	*128 Seneca School Rd.*		*Method:*	*Grab*
	Harmony, PA 16037			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*6/6/25*
			Time:	*9:30 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	9:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	2:00 PM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25	2:00 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	2:00 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 439

Customer

Facility Name:	*Seneca Valley H.S.*
Address:	*128 Seneca School Rd.*
	Harmony, PA 16037
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/3/25*
Time:	2:00 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/6/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	9:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	9:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	4:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/3/25	2:00 PM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/25	2:00 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/25	2:00 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor