



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 2269

Customer

Facility Name: *Holiday Inn - Campbells Run*

Address: *5311 Campbells Run Road*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/22/25*

Time: *8:30 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/25/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	8:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	8:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	8:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-11

Lab# 2269

Customer

Facility Name: *Holiday Inn - Campbells Run*

Address: *5311 Campbells Run Road*
Pittsburgh, PA 15205

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/22/25*

Time: *8:30 AM*

Method: *Grab*

Sample Final Analysis

Date: *7/25/25*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/22/25	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/22/25	8:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/22/25	8:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	8:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor