

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 APM 1

Lab# 2057

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Address: Park Dr.

Pittsburgh, PA 15227

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

 Date:
 6/23/25

 Time:
 3:15 PM

Method: Grab

Sample Final Analysis

 Date:
 6/26/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis Reporting limit Results Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 6/24/25 11:50 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/24/25 11:50 AM AΗ SM 9222B Standard plate count: 200/ml 6/23/25 6:10 PM AS SM 9215B 0/ml

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	3:15 PM	DW	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	3:15 PM	DW	DPD	
Turbidity:	2 NTU	1 - 2 NTU	6/23/25	3:15 PM	DW	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 APM 1

Lab# 2057

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Address: Park Dr.

Pittsburgh, PA 15227

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

 Date:
 6/23/25

 Time:
 3:15 PM

Method: Grab

Sample Final Analysis

 Date:
 6/26/25

 Time:
 9:00 AM

 Analyst:
 AS

Accredited Analysis Reporting limit Results Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 6/24/25 11:50 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/24/25 11:50 AM AΗ SM 9222B Standard plate count: 200/ml 6/23/25 6:10 PM AS SM 9215B 0/ml

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	3:15 PM	DW	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/23/25	3:15 PM	DW	DPD	
Turbidity:	2 NTU	1 - 2 NTU	6/23/25	3:15 PM	DW	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor