

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2191

Customer

Facility Name: Forest Heights Apts.

Address: 100 Forest Heights

Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 8/4/25

 Time:
 11:10 AM

 Method:
 Grab

Sample Final Analysis

 Date:
 8/7/25

 Time:
 11:20 AM

 Analyst:
 AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: SM 9222G Absent Absent 8/5/25 12:15 PM AS Total coliforms: 0/100mls 2/100mls 12:15 PM AS SM 9222B 8/5/25 200/ml 7:20 PM AS SM 9215B Standard plate count: 200/ml 8/4/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	11:10 AM	ВН	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:10 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:10 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 2191

Customer

Facility Name: Forest Heights Apts.

Address: 100 Forest Heights

Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 8/4/25

 Time:
 11:10 AM

 Method:
 Grab

Sample Final Analysis

 Date:
 8/7/25

 Time:
 11:20 AM

 Analyst:
 AS

Accredited Analysis Results Reporting limit **Analyst** Method Incubation Date/Time Escherichia Coli: SM 9222G Absent Absent 8/5/25 12:15 PM AS Total coliforms: 0/100mls 2/100mls 12:15 PM AS SM 9222B 8/5/25 200/ml 7:20 PM AS SM 9215B Standard plate count: 200/ml 8/4/25

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	8/4/25	11:10 AM	ВН	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:10 AM	ВН	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:10 AM	ВН	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor