



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

N-17

Laboratory Analysis Report Lab# 453

**Customer**

Facility Name: Fairfield Inn Butler

Address: 200 Fairfield Ln  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/7/25

Time: 12:55 PM

Method: Grab

**Sample Final Analysis**

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/7/25	12:55 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:55 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:55 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665

Lab ID No. 02-04041

N-17

Laboratory Analysis Report Lab# 453

**Customer**

Facility Name: Fairfield Inn Butler

Address: 200 Fairfield Ln  
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 7/7/25

Time: 12:55 PM

Method: Grab

**Sample Final Analysis**

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	11:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	11:15 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/7/25	12:55 PM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:55 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:55 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor