



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 367

Customer

Facility Name: YMCA - Uniontown
Address: 1 Ymca Lane
Uniontown, PA 15401

Sample Collection

Date: 2/9/26
Time: 12:45 PM
Method: Grab

Sample Final Analysis

Date: 2/12/26
Time: 10:30 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 2/10/26 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 2/10/26 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 2/9/26 | 5:20 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 2/9/26 | 12:45 PM | SH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 2/9/26 | 12:45 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 2/9/26 | 12:45 PM | SH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor