# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

| *Customer* | | *Sample Collection* | |
|---|---|---|---|
| *Facility Name:* | *Norberry* | *Date:* | *5/27/25* |
| | | *Time:* | *10:33 AM* |
| *Address:* | *Norberry Ct.* | *Method:* | *Grab* |
| | *Cranberry, PA 16066* | | |
| | | *Sample Final Analysis* | |
| *Matrix:* | *Recreational Water* | *Date:* | *5/30/25* |
| | | *Time:* | *9:00 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *1/0/00* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 5/27/25 | 10:33 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 10:33 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 10:33 AM | ZR | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)

# 1105 Washington Blvd
# Pittsburgh, Pennsylvania 15206
# (412) 661- 7665
# Laboratory Analysis Report

## Customer

| | |
|---|---|
| Facility Name: | Norberry |
| Address: | Norberry Ct.<br>Cranberry, PA 16066 |
| Matrix: | Recreational Water |
| Source Type: | Pool |

## Sample Collection

| | |
|---|---|
| Date: | 5/27/25 |
| Time: | 10:33 AM |
| Method: | Grab |

## Sample Final Analysis

| | |
|---|---|
| Date: | 5/30/25 |
| Time: | 9:00 AM |
| Analyst: | 1/0/00 |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 5/28/25 | 9:45 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 5/28/25 | 9:45 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 5/27/25 | 5:40 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 5/27/25 | 10:33 AM | ZR | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 5/27/25 | 10:33 AM | ZR | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 5/27/25 | 10:33 AM | ZR | Visual |

## Sample comments

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)