

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab# 442

Customer

Address:

Facility Name: Atria Cranberry Woods

3020 Fairport Lane

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25 Time: 12:11 PM

Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.7 SU	7.2 - 7.8 SU	8/12/25	12:11 PM	ZS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:11 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:11 PM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab# 442

Customer

Address:

Facility Name: Atria Cranberry Woods

3020 Fairport Lane

Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/25 Time: 12:11 PM

Method: Grab

Sample Final Analysis

Date: 8/15/25

Time: 9:00 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.7 SU	7.2 - 7.8 SU	8/12/25	12:11 PM	ZS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/12/25	12:11 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	12:11 PM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith