Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2507

Customer			*Sample Collection*	
Facility Name:	*Stanford Court*		*Date:*	*7/9/25*
			Time:	8:00 AM
Address:	*1200 Stanford Ct.*		*Method:*	*Grab*
	Coraopolis, PA 15108			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/12/25*
			Time:	*8:30 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	4:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	4:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/9/25	8:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	8:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2507

Customer

Facility Name:	*Stanford Court*
Address:	*1200 Stanford Ct.*
	Coraopolis, PA 15108
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/9/25*
Time:	8:00 AM
Method:	*Grab*

Sample Final Analysis

Date:	*7/12/25*
Time:	*8:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	4:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	4:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/9/25	8:00 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/9/25	8:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	8:00 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor