



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**

Lab ID No. 02-04041

**S-15**

**Lab# 371**

## Laboratory Analysis Report

### Customer

Facility Name: Gold Fish South Hills

Address: 690 Crosswinds Dr.  
McMurray, PA 15317

Matrix: Recreational Water

Source Type: Pool

### Sample Collection

Date: 8/26/25

Time: 10:12 AM

Method: Grab

### Sample Final Analysis

Date: 8/29/25

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/26/25	10:12 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	10:12 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	10:12 AM	AF	Visual

### Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor