



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2375

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	OakHill - Wadsworth		<b><u>Sample Collection</u></b>			
Address:	480 Oak Hill Dr Pittsburgh, Pa 15213		Date: 7/7/25 Time: 12:00 PM Method: Grab			
Matrix:	Recreational Water		<b><u>Sample Final Analysis</u></b>			
Source Type:	Pool		Date: 7/10/25 Time: 9:30 AM Analyst: AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	12:00 PM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:00 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:00 PM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 3

Lab# 2375

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	OakHill - Wadsworth		<b><u>Sample Collection</u></b>			
Address:	480 Oak Hill Dr Pittsburgh, Pa 15213		Date: 7/7/25 Time: 12:00 PM Method: Grab			
Matrix:	Recreational Water		<b><u>Sample Final Analysis</u></b>			
Source Type:	Pool		Date: 7/10/25 Time: 9:30 AM Analyst: AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:41 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	12:00 PM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	12:00 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	12:00 PM	LM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor