



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 296

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 7/28/25
Time: 11:30 AM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:30 AM	AH	SM 9222B
Standard plate count:	300/ml	200/ml	7/28/25	5:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/28/25	11:30 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:30 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:30 AM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 296

Customer

Facility Name: Steel Valley High School

Address: 3113 Main Street
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 7/28/25
Time: 11:30 AM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:30 AM	AH	SM 9222B
Standard plate count:	300/ml	200/ml	7/28/25	5:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/28/25	11:30 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:30 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:30 AM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor