Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2106

Customer	*American Pools Management* *3261 Babcock Blvd.* *Pittsburgh, PA 15237*

Facility Name:	*City View*	***Sample Collection***	
		Date:	*7/1/25*
		Time:	10:55 AM
Address:	*1420 Centre Ave*	*Method:*	*Grab*
	Pittsburgh, PA 15219		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/4/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	10:55 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/1/25	10:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:55 AM	LM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer	American Pools Management
	3261 Babcock Blvd.
	Pittsburgh, PA 15237

		Sample Collection	
Facility Name:	City View	*Date:*	7/1/25
		Time:	10:55 AM
Address:	1420 Centre Ave	*Method:*	Grab
	Pittsburgh, PA 15219		
		Sample Final Analysis	
Matrix:	Recreational Water	*Date:*	7/4/25
		Time:	9:30 AM
Source Type:	Pool	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	300/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	10:55 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/1/25	10:55 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	10:55 AM	LM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor