Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2273

Customer

Facility Name:	*Hosanna Camp*		
Address:	*400 Sherwood Rd*		
	Pittsburgh, PA 15221		
Matrix:	*Recreational Water*		
Source Type:	*Deep End*		

Sample Collection

Date:	*5/28/25*
Time:	3:20 PM
Method:	*Grab*

Sample Final Analysis

Date:	*5/31/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/28/25	3:20 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	3:20 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	3:20 PM	EH	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2273

Customer

Facility Name:	Hosanna Camp
Address:	400 Sherwood Rd
	Pittsburgh, PA 15221
Matrix:	Recreational Water
Source Type:	Deep End

Sample Collection

Date:	5/28/25
Time:	3:20 PM
Method:	Grab

Sample Final Analysis

Date:	5/31/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	5:36 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/28/25	3:20 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	3:20 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	3:20 PM	EH	Visual

Sample comments

(signature: Andre Smith)

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor