

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2653

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Sample Collection

Facility Name: Edge 1909 Date: 8/27/25
Time: 10:45 AM
Address: 1909 Waterfront Place Method: Grab

Pittsburgh, PA 15225

Matrix: 1909 Waterfront Place Sample Final Analysis
Date: 8/30/25

Source Type: Pool Time: 8:30 AM
Analyst: AS

Reporting limit Accredited Analysis Results **Incubation Date/Time** Analyst Method Escherichia Coli: Absent Absent 8/28/25 10:40 AM AS SM 9222G Total coliforms: 0/100mls 2/100mls 8/28/25 10:40 AM AS SM 9222B SL Standard plate count: 100/ml 200/ml 8/27/25 5:40 PM SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/27/25	10:45 AM	ВН	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/27/25	10:45 AM	ВН	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/27/25	10:45 AM	ВН	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)