



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 322

Customer

Facility Name: Upper St. Clair Rec.
Address: 1551 Mayview Road
Upper St. Clair, PA 15241

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 9/9/25
Time: 3:31 PM
Method: Grab

Sample Final Analysis

Date: 9/12/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|-----------------------|----------|----------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 9/10/25 10:10 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/10/25 10:10 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/9/25 5:50 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

| | | | | | |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 9/10/25 10:30 AM | SL | SM 9213C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | |
|------------|----------|----------------|----------------|----|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/9/25 3:31 PM | MM | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 9/9/25 3:31 PM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/9/25 3:31 PM | MM | Visual |

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor