



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2004

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Accord -Avonworth
Address: 498 Camp Horne Road
Pittsburgh, PA 15237

Date: 6/17/25
Time: 11:04 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Deep End

Date: 6/20/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25 10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25 10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25 5:00 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25 11:04 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/17/25 11:04 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25 11:04 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2004

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Accord -Avonworth
Address: 498 Camp Horne Road
Pittsburgh, PA 15237

Date: 6/17/25
Time: 11:04 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Deep End

Date: 6/20/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/17/25	5:00 PM	EB	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/17/25	11:04 AM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	6/17/25	11:04 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	11:04 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor