



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2290**

**Customer**

Facility Name: *Ingomar Swim Club*  
Address: *1512 Ingomar Heights Rd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

Date: *8/5/25*  
Time: *2:26 PM*  
Method: *Grab*

Matrix: *Recreational Water*

**Sample Final Analysis**

Date: *8/8/25*  
Time: *8:30 AM*  
Analyst: *AS*

Source Type: *Baby Pool*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/6/25               | 2:40 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/6/25               | 2:40 PM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/5/25               | 6:45 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/5/25    | 2:26 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 8/5/25    | 2:26 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/5/25    | 2:26 PM | MM      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2290**

**Customer**

Facility Name: *Ingomar Swim Club*  
Address: *1512 Ingomar Heights Rd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

Date: *8/5/25*  
Time: *2:26 PM*  
Method: *Grab*

Matrix: *Recreational Water*

**Sample Final Analysis**

Date: *8/8/25*  
Time: *8:30 AM*  
Analyst: *AS*

Source Type: *Baby Pool*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/6/25               | 2:40 PM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/6/25               | 2:40 PM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/5/25               | 6:45 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 8/5/25    | 2:26 PM | MM      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 8/5/25    | 2:26 PM | MM      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/5/25    | 2:26 PM | MM      | Visual |

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor