



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 359**

**Customer**

Facility Name: YMCA - Mon-Valley  
Address: 101 Taylor Run Road  
Monongahela, PA 15063

**Sample Collection**

Date: 12/15/25  
Time: 3:00 PM  
Method: Grab

**Sample Final Analysis**

Date: 12/18/25  
Time: 11:30 AM  
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/16/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/16/25	11:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/15/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.2 SU	7.2 - 7.8 SU	12/15/25	3:00 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/15/25	3:00 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/15/25	3:00 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor