



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-17

Lab# 437

**Customer**

Facility Name: Grove City College  
Address: 100 Campus Dr.  
Grove City, PA 16127

Matrix: Recreational Water  
Source Type: Rec Pool

**Sample Collection**

Date: 6/16/25  
Time: 2:50 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/19/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:15 AM	EB
Total coliforms:	0/100mls	2/100mls	6/17/25	11:15 AM	EB
Standard plate count:	300/ml	200/ml	6/16/25	5:45 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	2:50 PM	BH
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:50 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:50 PM	BH

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-17

Lab# 437

**Customer**

Facility Name: Grove City College  
Address: 100 Campus Dr.  
Grove City, PA 16127

Matrix: Recreational Water  
Source Type: Rec Pool

**Sample Collection**

Date: 6/16/25  
Time: 2:50 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/19/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:15 AM	EB
Total coliforms:	0/100mls	2/100mls	6/17/25	11:15 AM	EB
Standard plate count:	300/ml	200/ml	6/16/25	5:45 PM	SL

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	2:50 PM	BH
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/25	2:50 PM	BH
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	2:50 PM	BH

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor