



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 13**

**Lab# 454**

**Customer**

**Facility Name:** Hampton Inn  
**Address:** 3000 Mossdale Blvd.  
Monroeville, PA 15146

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 8/26/25  
**Time:** 1:32 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/29/25  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	11:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	11:00 AM	AS	SM 9222B
Standard plate count:	5700/ml	200/ml	8/26/25	4:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/26/25	1:32 PM	EH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/26/25	1:32 PM	EH	DPD
Turbidity:	2 NTU	1 - 2 NTU	8/26/25	1:32 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor