

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 076

Customer				Sample Collection			
Facility Name:	Courtyard by	Marriott		Date:	7/29/25		
				Time:	12:13 PM		
Address:	1800 Tanger	Blvd.		Method:	Grab		
	Washington,	PA 15301					
				Sample Final	<u>Analysis</u>		
Matrix:	Recreational	Water		Date:	8/1/25		
_	_			Time:	9:00 AN		
Source Type:	Spa			Analyst:	AS	5	
Accredited Analysis	Results	Reporting limit	Incubatio	n Date/Time	Analyst	Method	
Accredited Analysis Escherichia Coli:	Results Absent	Absent	7/30/25	n Date/Time 10:00 AM	Analyst AH	Method SM 9222G	
-							
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	АН	SM 9222G	

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/25	12:13 PM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/29/25	12:13 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	12:13 PM	GR	Visual

7/30/25

2/100mls

Sample comments

Fecal Streptococcus

0/100mls

andre Smith

10:50 AM

EΒ

SM 9230C

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 076

Customer				Sample Collection			
Facility Name:	Courtyard by	Marriott		Date:	7/29/25		
				Time:	12:13 PM		
Address:	1800 Tanger	Blvd.		Method:	Grab		
	Washington,	PA 15301					
				Sample Final	<u>Analysis</u>		
Matrix:	Recreational	Water		Date:	8/1/25		
_	_			Time:	9:00 AN		
Source Type:	Spa			Analyst:	AS	5	
Accredited Analysis	Results	Reporting limit	Incubatio	n Date/Time	Analyst	Method	
Accredited Analysis Escherichia Coli:	Results Absent	Absent	7/30/25	n Date/Time 10:00 AM	Analyst AH	Method SM 9222G	
-							
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	АН	SM 9222G	

Field Analysis	Results	Reporting limit	Da	ate/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/25	12:13 PM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/29/25	12:13 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	12:13 PM	GR	Visual

7/30/25

2/100mls

Sample comments

Fecal Streptococcus

0/100mls

andre Smith

10:50 AM

EΒ

SM 9230C

(When exceeding reporting limit pool or spa is unfit)