



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 465**

**Customer**

Facility Name: Towers Pool  
Address: 1206 Bluff St.  
Pittsburgh, PA 15282

**Sample Collection**

Date: 10/14/25  
Time: 12:35 PM  
Method: Grab

Matrix: Recreational Water  
Source Type: Pool Deep

**Sample Final Analysis**

Date: 10/17/25  
Time: 11:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/15/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/15/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/14/25	5:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/14/25	12:35 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	10/14/25	12:35 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/14/25	12:35 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor