



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2300**

**Customer**

**Facility Name:** Jefferson Point  
**Address:** 6400 Jefferson Point Circle  
Jefferson Hills, PA 15025

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 8/6/25  
**Time:** 1:42 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/8/25  
**Time:** 2:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	8/6/25	1:42 PM	ZS	DPD
Chlorine:	8.5 mg/l	1.0 - 5.0 mg/l	8/6/25	1:42 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	1:42 PM	ZS	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 2300**

**Customer**

**Facility Name:** Jefferson Point  
**Address:** 6400 Jefferson Point Circle  
Jefferson Hills, PA 15025

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 8/6/25  
**Time:** 1:42 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 8/8/25  
**Time:** 2:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/25	3:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	8/6/25	1:42 PM	ZS	DPD
Chlorine:	8.5 mg/l	1.0 - 5.0 mg/l	8/6/25	1:42 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	1:42 PM	ZS	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor