



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 216

Customer

Facility Name: Longwood at Oakmont

Address: 500 Rt. 909
Verona, PA 15147

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 1/6/26

Time: 7:51 AM

Method: Grab

Sample Final Analysis

Date: 1/9/26

Time: 10:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/7/26 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/7/26 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/6/26 | 4:00 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---------------------|----------|-----------------|----------------------|----------|---------|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 1/7/26 | 10:40 AM | JC | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 1/6/26 | 7:51 AM | AMH | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 1/6/26 | 7:51 AM | AMH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/6/26 | 7:51 AM | AMH | Visual |

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)