



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-1**

**Lab# 060**

**Customer**

**Facility Name:** Comfort Inn  
**Address:** 699 Rodi Rd.  
Pittsburgh, PA 15235

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 2/3/26  
**Time:** 9:55 AM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 2/6/26  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/3/26	9:55 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/3/26	9:55 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26	9:55 AM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor