



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 475

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Altoona HS	Date:	9/22/25			
Address:	1404 6th Ave Altoona, PA 16602	Time:	2:30 PM			
Matrix:		<u>Sample Final Analysis</u>				
Source Type:	Recreational Water	Date:	9/25/25			
	Pool	Time:	11:00 AM			
		Analyst:	AS			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	9/23/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	9/22/25	2:30 PM	DNP	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/22/25	2:30 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	2:30 PM	DNP	Visual

Sample comments

A handwritten signature in black ink that reads "Andre Smith".

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor