



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 213

Customer

Facility Name: Langley High School

Address: 2940 Sheradan Blvd.
Pittsburgh, PA 15204

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 8/4/25

Time: 2:12 PM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	8/5/25	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	8/5/25	10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	A	8/4/25	4:21 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.5 SU	A	8/4/25	2:12 PM	ZS	DPD
Chlorine:	4.0 mg/l	B	8/4/25	2:12 PM	ZS	DPD
Turbidity:	1 NTU	A	8/4/25	2:12 PM	ZS	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 213

Customer

Facility Name: Langley High School

Address: 2940 Sheradan Blvd.
Pittsburgh, PA 15204

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 8/4/25

Time: 2:12 PM

Method: Grab

Sample Final Analysis

Date: 8/7/25

Time: 11:20 AM

Analyst: AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	8/5/25	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	8/5/25	10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	A	8/4/25	4:21 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.5 SU	A	8/4/25	2:12 PM	ZS	DPD
Chlorine:	4.0 mg/l	B	8/4/25	2:12 PM	ZS	DPD
Turbidity:	1 NTU	A	8/4/25	2:12 PM	ZS	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor