



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 462**

**Customer**

**Facility Name:** *Rivers Club*  
**Address:** *301 Grant St*  
*Pittsburgh, PA 15212*

**Sample Collection**

**Date:** *1/27/26*  
**Time:** *12:05 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *1/30/26*  
**Time:** *11:00 AM*  
**Analyst:** *AS*

**Source Type:** *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	1/28/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	1/27/26	12:05 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/27/26	12:05 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	12:05 PM	BH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)