



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Service

Lab# 379

Customer

Facility Name: PPG Paints Arena

Sample Collection

Date: 12/1/25

Address: 1001 Fifth Ave
Pittsburgh, PA 15219

Time: 11:40 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 12/4/25

Source Type: Spa

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/2/25	9:35 AM	AS SM 9222G
Total coliforms:	0/100mls	2/100mls	12/2/25	9:35 AM	AS SM 9222B
Standard plate count:	0/ml	200/ml	12/1/25	4:15 PM	AS SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/2/25	10:55 AM	AS SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.3 SU	7.2 - 7.8 SU	12/1/25	11:40 AM	RD DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/1/25	11:40 AM	RD DPD
Turbidity:	1 NTU	1 - 2 NTU	12/1/25	11:40 AM	RD Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)