



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2653

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Edge 1909

Date: 6/10/25

Address: 1909 Waterfront Place
Pittsburgh, PA 15225

Time: 9:30 AM

Method: Grab

Sample Final Analysis

Matrix: 1909 Waterfront Place

Date: 6/13/25

Time: 9:30 AM

Source Type: Pool

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/10/25	9:30 AM	WM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/10/25	9:30 AM	WM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:30 AM	WM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2653

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Edge 1909

Date: 6/10/25

Time: 9:30 AM

Method: Grab

Address: 1909 Waterfront Place
Pittsburgh, PA 15225

Sample Final Analysis

Matrix: 1909 Waterfront Place

Date: 6/13/25

Time: 9:30 AM

Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/11/25	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/11/25	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/10/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	6/10/25	9:30 AM	WM	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/10/25	9:30 AM	WM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/10/25	9:30 AM	WM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor