



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 129

Customer

Facility Name: Hampton Inn Belle Vernon
Address: 1525 Broad Ave Ext
Belle Vernon, PA 15012

Sample Collection

Date: 9/15/25
Time: 10:40 AM
Method: Grab

Sample Final Analysis

Date: 9/18/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/25 10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/25 10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/25 4:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	9/15/25 10:40 AM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	9/15/25 10:40 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/25 10:40 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor