



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**SERVICE**

**Lab# 121**

**Customer**

**Facility Name:** Hampton Inn

**Address:** 301 West Waterfront Dr.  
Pittsburgh, PA 15120

**Matrix:** Hampton Inn

**Source Type:** Pool

**Sample Collection**

**Date:** 8/18/25

**Time:** 1:00 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 8/21/25

**Time:** 9:00 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/19/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/19/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	8/18/25	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/18/25	1:00 PM	DS	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/18/25	1:00 PM	DS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/18/25	1:00 PM	DS	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor