



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2149**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Deauville Park Apts*  
  
*Address:*      *540 Deauville Drive*  
*Monroeville, PA 15146*

**Sample Collection**

*Date:*      *7/1/25*  
*Time:*      *12:31 PM*  
*Method:*      *Grab*

*Matrix:*      *Recreational Water*  
  
*Source Type:*      *Pool*

**Sample Final Analysis**

*Date:*      *7/4/25*  
*Time:*      *9:30 AM*  
*Analyst:*      *AS*


Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	12:31 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/1/25	12:31 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	12:31 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2149**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name:*      *Deauville Park Apts*  
*Address:*      *540 Deauville Drive*  
*Monroeville, PA 15146*

*Date:*      *7/1/25*  
*Time:*      *12:31 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Matrix:*      *Recreational Water*  
*Source Type:*      *Pool*

*Date:*      *7/4/25*  
*Time:*      *9:30 AM*  
*Analyst:*      *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	9:10 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	9:10 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	3:25 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/1/25	12:31 PM	EH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/1/25	12:31 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	12:31 PM	EH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor