

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2756

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Artisan at Robinson

Address: 301 Hightower Blvd.

Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/17/25

Time: 7:45 AM Method: Grab

Sample Final Analysis

 Date:
 6/20/25

 Time:
 9:00 AM

 Analyst:
 AS

**Accredited Analysis** Reporting limit Results Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 6/18/25 9:00 AM EB SM 9222G Total coliforms: 0/100mls 2/100mls 6/18/25 EΒ 9:00 AM SM 9222B Standard plate count: 5700/ml 200/ml 6/17/25 3:03 PM ΕB SM 9215B **Field Analysis Results Reporting limit** Date/Time **Analyst** Method 8.0 SU 7.2 - 7.8 SU 7:45 AM VΗ **DPD** pH: 6/17/25 Chlorine: 3.0 mg/l 1.0 - 5.0 mg/l 6/17/25 7:45 AM VH DPD Turbidity: 1 NTU 1 - 2 NTU 6/17/25 7:45 AM VΗ Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2756

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Artisan at Robinson

Address: 301 Hightower Blvd.

Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/17/25

Time: 7:45 AM Method: Grab

Sample Final Analysis

 Date:
 6/20/25

 Time:
 9:00 AM

 Analyst:
 AS

**Accredited Analysis** Reporting limit Results Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 6/18/25 9:00 AM EB SM 9222G Total coliforms: 0/100mls 2/100mls 6/18/25 EΒ 9:00 AM SM 9222B Standard plate count: 5700/ml 200/ml 6/17/25 3:03 PM ΕB SM 9215B **Field Analysis Results Reporting limit** Date/Time **Analyst** Method 8.0 SU 7.2 - 7.8 SU 7:45 AM VΗ **DPD** pH: 6/17/25 Chlorine: 3.0 mg/l 1.0 - 5.0 mg/l 6/17/25 7:45 AM VH DPD Turbidity: 1 NTU 1 - 2 NTU 6/17/25 7:45 AM VΗ Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor