



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 2173

**Customer**

Facility Name: *Edgeworth Club*  
Address: *511 East Drive  
Sewickley, PA 15143*  
Matrix: *Recreational Water*  
Source Type: *Baby Pool*

**Sample Collection**

Date: *6/4/25*  
Time: *12:45 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *6/6/25*  
Time: *4:00 PM*  
Analyst: *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/4/25	3:50 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	3:50 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	3:15 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/4/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	12:45 PM	VH	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 2173

**Customer**

Facility Name: *Edgeworth Club*  
Address: *511 East Drive  
Sewickley, PA 15143*  
Matrix: *Recreational Water*  
Source Type: *Baby Pool*

**Sample Collection**

Date: *6/4/25*  
Time: *12:45 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *6/6/25*  
Time: *4:00 PM*  
Analyst: *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
Escherichia Coli:	Absent	Absent	6/4/25	3:50 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	3:50 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/25	3:15 PM	EB	SM 9215B

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>	
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	12:45 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/4/25	12:45 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	12:45 PM	VH	Visual

**Sample comments**

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor