



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2715

Customer

Facility Name: Traditions of America-Richland

Address: 101 Patriot Lane
Glenshaw, PA 15116

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/30/25

Time: 12:22 PM

Method: Grab

Sample Final Analysis

Date: 7/3/25

Time: 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:44 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	12:22 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25	12:22 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	12:22 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2715

Customer

Facility Name: *Traditions of America-Richland*
Address: *101 Patriot Lane*
Glenshaw, PA 15116

Sample Collection

Date: *6/30/25*
Time: *12:22 PM*
Method: *Grab*

Sample Final Analysis

Date: *7/3/25*
Time: *9:30 AM*
Analyst: *AS*

Matrix: *Recreational Water*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/30/25	3:44 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/30/25	12:22 PM	GR	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/30/25	12:22 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	12:22 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor