



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041
N-17

Lab# 434

<u>Customer</u>		<u>Sample Collection</u>		<u>Sample Final Analysis</u>		
Facility Name:	SRU Field House	Date:	8/25/25			
Address:	101 Field House Rd. Slippery Rock, PA 16057	Time:	2:25 PM			
Matrix:	Recreational Water	Method:	Grab			
Source Type:	Pool					
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/26/25	10:40 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/26/25	10:40 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/25/25	5:30 PM	AS	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	8/25/25	2:25 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/25/25	2:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/25/25	2:25 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor