



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report**

Lab ID No. 02-04041

C-10

Lab# 044

Customer

Facility Name: Carnegie Mellon
Address: 5000 Forbes Ave.
Pittsburgh, PA 15213
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 6/2/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 6/5/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:30 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	11:30 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	10:15 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	10:15 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:15 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



**Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report**

Lab ID No. 02-04041

C-10

Lab# 044

Customer

Facility Name: Carnegie Mellon
Address: 5000 Forbes Ave.
Pittsburgh, PA 15213
Matrix: Recreational Water
Source Type: Spa

Sample Collection

Date: 6/2/25
Time: 10:15 AM
Method: Grab

Sample Final Analysis

Date: 6/5/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	AH
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	AH
Standard plate count:	0/ml	200/ml	6/2/25	3:30 PM	SL

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	11:30 AM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/25	10:15 AM	LM
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	10:15 AM	LM
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	10:15 AM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor