Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab#   091

Customer

		Sample Collection	
Facility Name:	*Doubletree Hotel*	*Date:*	*8/11/25*
		Time:	3:35 PM
Address:	*101 Doubletree Dr.*	*Method:*	*Grab*
	Pittsburgh, PA, 15205		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/14/25*
		Time:	*9:00 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	3:35 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:35 PM	CW	DPD
Turbidity:	2 NTU	1 - 2 NTU	8/11/25	3:35 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 091

Customer
Facility Name:	*Doubletree Hotel*
Address:	*101 Doubletree Dr.*
	Pittsburgh, PA, 15205
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection
Date:	*8/11/25*
Time:	3:35 PM
Method:	*Grab*

Sample Final Analysis
Date:	*8/14/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	3:35 PM	CW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:35 PM	CW	DPD
Turbidity:	2 NTU	1 - 2 NTU	8/11/25	3:35 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor