



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2242

Customer

Facility Name: Hawthorne Commons
Address: 214 Sycamore Dr.
Seven Fields, PA 16046

Sample Collection

Date: 7/15/25
Time: 10:10 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25 10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25 10:50 AM	AH	SM 9222B
Standard plate count:	250/ml	200/ml	7/15/25 4:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25 10:10 AM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25 10:10 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25 10:10 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2242

Customer

Facility Name: Hawthorne Commons
Address: 214 Sycamore Dr.
Seven Fields, PA 16046

Sample Collection

Date: 7/15/25
Time: 10:10 AM
Method: Grab

Matrix: Recreational Water
Source Type: Pool

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25 10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25 10:50 AM	AH	SM 9222B
Standard plate count:	250/ml	200/ml	7/15/25 4:20 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/15/25 10:10 AM	ZR	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25 10:10 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25 10:10 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor