



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 2680

Customer

Facility Name: Club @ Shadow Lakes
Address: 2000 Beaver Lakes Blvd.
Aliquippa, PA 15001

Sample Collection

Date: 8/25/25
Time: 11:07 AM
Method: Grab

Sample Final Analysis

Date: 8/28/25
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Wading Pool

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/26/25 | 10:15 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/26/25 | 10:15 AM | AS | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 8/25/25 | 5:20 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|------------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/25/25 | 11:07 AM | AMH DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 8/25/25 | 11:07 AM | AMH DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/25/25 | 11:07 AM | AMH Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor