



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 431

Customer

Facility Name: *Upper St. Clair High School*

Address: *1825 McLaughlin Run Rd.*
Upper St. Clair, PA 15241

Matrix: *Recreational Water*

Source Type: *Dive Shallow*

Sample Collection

Date: *7/7/25*

Time: *3:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	3:15 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	3:15 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	3:15 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 431

Customer

Facility Name: *Upper St. Clair High School*

Address: *1825 McLaughlin Run Rd.*
Upper St. Clair, PA 15241

Matrix: *Recreational Water*

Source Type: *Dive Shallow*

Sample Collection

Date: *7/7/25*

Time: *3:15 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/8/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	5:50 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/7/25	3:15 PM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/7/25	3:15 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	3:15 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor