



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 028

Customer

Facility Name: *Burrell High School*
Address: *1021 Puckety Church Rd.*
Lower Burrell, PA 15068

Sample Collection

Date: *2/3/26*
Time: *12:35 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *2/6/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	2/4/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/4/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/3/26	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/3/26	12:35 PM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/3/26	12:35 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/3/26	12:35 PM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)