



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 048**

**Customer**

**Facility Name:** Chartiers Valley High School

**Address:** 50 Thoms Run Rd.  
Bridgeville, PA 15017

**Matrix:** Recreational Water

**Source Type:** Pool Shallow

**Sample Collection**

**Date:** 10/8/25

**Time:** 8:15 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 10/10/25

**Time:** 6:00 PM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/8/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/8/25	5:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	10/8/25	4:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	10/8/25	8:15 AM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/8/25	8:15 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/8/25	8:15 AM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor