



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 411**

**Customer**

**Facility Name:** *Fairfield Inn*  
**Address:** *1004 Sutherland Dr.*  
*Pittsburgh, PA 15205*

**Matrix:** *Recreational Water*

**Source Type:** *Spa*

**Sample Collection**

**Date:** *8/12/25*  
**Time:** *10:00 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *8/15/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/13/25 9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25 2:56 PM	AH	SM 9215B

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/13/25 11:30 AM	EB	SM 9230C
---------------------	----------	----------	------------------	----	----------

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.2 SU	7.2 - 7.8 SU	8/12/25 10:00 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/12/25 10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 10:00 AM	VH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 411**

**Customer**

**Facility Name:** *Fairfield Inn*  
**Address:** *1004 Sutherland Dr.*  
*Pittsburgh, PA 15205*

**Matrix:** *Recreational Water*

**Source Type:** *Spa*

**Sample Collection**

**Date:** *8/12/25*  
**Time:** *10:00 AM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *8/15/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/13/25 9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25 9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25 2:56 PM	AH	SM 9215B

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/13/25 11:30 AM	EB	SM 9230C
---------------------	----------	----------	------------------	----	----------

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.2 SU	7.2 - 7.8 SU	8/12/25 10:00 AM	VH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/12/25 10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25 10:00 AM	VH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor