



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2433

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Alden South Hills
Address: 5492 Youngridge Dr.
Pittsburgh, PA 15236

Date: 7/14/25
Time: 9:11 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	7/14/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	9:11 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	9:11 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	9:11 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2433

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Alden South Hills
Address: 5492 Youngridge Dr.
Pittsburgh, PA 15236

Date: 7/14/25
Time: 9:11 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 7/17/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	10:15 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	10:15 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	7/14/25	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/14/25	9:11 AM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/14/25	9:11 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	9:11 AM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor