



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2062

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

**Sample Collection**

Date: 8/11/25

Address: 8190 Rochester Rd  
Pittsburgh, PA 15237

Time: 11:59 AM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 8/14/25

Source Type: Deep End

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	8/11/25	11:59 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	11:59 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	11:59 AM	MM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools And Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661- 7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2062

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name: Brook Park Swim Club

**Sample Collection**

Date: 8/11/25

Address: 8190 Rochester Rd  
Pittsburgh, PA 15237

Time: 11:59 AM

Method: Grab

Matrix: Recreational Water

**Sample Final Analysis**

Date: 8/14/25

Source Type: Deep End

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	8/11/25	11:59 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	11:59 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	11:59 AM	MM	Visual

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor