



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 241

Customer

Facility Name: *Obama High School*

Address: *515 N. Highland Ave*
Pittsburgh, PA 15206

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *7/9/25*
Time: *9:50 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/11/25*
Time: *4:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	A	7/9/25	5:25 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.5 SU	A	7/9/25	9:50 AM	ZS	DPD
Chlorine:	4.0 mg/l	B	7/9/25	9:50 AM	ZS	DPD
Turbidity:	1 NTU	A	7/9/25	9:50 AM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 241

Customer

Facility Name: Obama High School
Address: 515 N. Highland Ave
Pittsburgh, PA 15206

Matrix: Recreational Water

Source Type: Pool Deep

Sample Collection

Date: 7/9/25
Time: 9:50 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 4:00 PM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	A	7/9/25	5:25 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.5 SU	A	7/9/25	9:50 AM	ZS	DPD
Chlorine:	4.0 mg/l	B	7/9/25	9:50 AM	ZS	DPD
Turbidity:	1 NTU	A	7/9/25	9:50 AM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor