

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 3360

Customer

Facility Name: Franklin Towne Condo

Address: 200 Rain Print Lane

Murrysville PA 15668

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7
Time: 8

7/29/25 8:10 AM

Method: Grab

Sample Final Analysis

Date: Time: 8/1/25 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	3:40 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	8:10 AM	EH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/29/25	8:10 AM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	8:10 AM	EH	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 3360

Customer

Facility Name: Franklin Towne Condo

Address: 200 Rain Print Lane

Murrysville PA 15668

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7
Time: 8

7/29/25 8:10 AM

Method: Grab

Sample Final Analysis

Date: Time: 8/1/25 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	9:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	9:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	3:40 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.4 SU	7.2 - 7.8 SU	7/29/25	8:10 AM	EH	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/29/25	8:10 AM	EH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	8:10 AM	EH	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor